

# NOTICE TO ALL FIRE SUPPRESSION SYSTEM CONTRACTORS

AS OF JULY 1, 2007, A FIRE PROTECTION SYSTEMS PERMIT MUST BE OBTAINED PRIOR TO THE INSTALLATION OF ANY HOOD AND DUCT FIRE SUPPRESSION SYSTEM.

PLANS AND A PERMIT APPLICATION MUST BE SUBMITTED TO THE DEPARTMENT OF PERMITTING SERVICES FOR APPROVAL.

CONTRACTORS MUST BE LICENSED THROUGH THE STATE OF MARYLAND AND THE MONTGOMERY COUNTY DIVISION OF FIRE CODE ENFORCEMENT

ALL SUBMITTALS MUST INCLUDE THE FOLLOWING INFORMATION:

- Plans (to scale or dimensioned) showing the area to be protected, hoods, ducts, interface with the fire alarm system, system detectors (if any), fusible links, piping, nozzles, fuel shut off, agent storage containers, manual actuation devices.
- Piping layout.
- Catalog cut submittals on all equipment to be used.
- Type of hazard being protected (including the types of oils to be used).
- Calculations including the size, length, arrangement and the exposure to the hazard. Amount of agent. The description of nozzles so that adequacy of the system can be evaluated.
- Type of extinguishing agent
- Type of system (engineered, pre-engineered).