



MONTGOMERY COUNTY FIRE AND RESCUE SERVICE

Isiah Leggett
County Executive

Thomas W. Carr, Jr.
Fire Chief

COLD WEATHER HYDROSTATIC TEST CERTIFICATION

ADDRESS: _____

DATE: _____ TIME: _____ A/P # _____

This document certifies that the sprinkler contractor has filled the entire sprinkler system with water and pressurized the sprinkler piping to _____ psi for 2 hours.

The entire sprinkler system has been visually checked for leaks/breaks at each joint, coupling, and piping throughout the structure. Any leaks or breaks have been corrected before concealment of the sprinkler system piping.

We the undersigned certify and affirm that we have witnessed the hydrostatic testing of the sprinkler system as stated above and have complied with all specifications listed.

SIGN _____
Sprinkler Contractor Signature

SIGN _____
General Contractor Signature

PRINT _____
Sprinkler Contractor Printed Name

PRINT _____
General Contractor Printed Name

IMPORTANT

By signing this document the General and Sprinkler Contractors acknowledge that this home will again have the sprinkler system pressurized to test pressure at time of final inspection and it must be witnessed by the fire marshal.

11/12/07